



Broadcast Devices, Inc.

Technical Reference Manual

***SWP-206 8 Channel Antenna RF Power Monitor System For
Use with the BDI DPS-100D Power Metering Systems***

Broadcast Devices, Inc.

Tel. (914) 737-5032

Website: <https://Broadcast-Devices.com>

Customer Service: customer.service@broadcast-devices.com

Rev. I March 2026

LAN Firmware 5.10.7 and higher

SWP Firmware 3.6.19GD and higher

Table of Contents

Section	Page
I. Introduction	3
II. Description	3
III. Installation Considerations	3
IV. Rack Equipment Location and Connection DPS-100D Interconnection	4-5
V. Interlock Configuration and Connections	6-8
VI. Remote Control/External Interlock Input Connections	8-9
VII. Operation/LAN Configuration	9-12
VIII. BDI Stack Graphical User Interface	13
IX. SNMP v2 Connectivity	13
X. Warranty	14
XI. Specifications	15

Regulatory and Safety Information

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

I. Introduction

The SWP-206 Digi Monitor was developed by BDI to display data from up to 8 DPS-100D Digital Power Sensors in a single rack unit display. The SWP-206 can measure up to 8 directional coupler forward/reflected outputs simultaneously providing interlock control to safeguard against damage caused by high reflected power. The SWP-206 displays forward/reflected power, temperature and line pressure measurements can be performed by the addition of optional BDI TMP-100 temperature sensors and PSW-100 pressure sensors connected to accompanying DPS-100D Power sensor systems. Simple RS-485 serial connection via standard Category 5/6 cabling is used to connect the various DPS-100D power sensors to the SWP-206 chassis.

We recommend that the installer read this technical reference manual in its entirety before attempting the installation. The BDI SWP series protection systems are designed to provide reliable protection to antenna systems for many years to come if installed and operated properly.

II. Description of system

The SWP-206 Digi Monitor series protection system has been upgraded to communicate with the DPS-100D RF Power sensor. A single Ethernet cable interface to up to eight DPS-100D sensors can be supported. RS485 communication protocol allows for addressing of each sensor. Each DPS-100D sensor. The system can be monitored via the BDI Stack Graphical User Interface and by SNMP capable hardware and software. The SWP-206 acts as an SNMP v2 agent device.

III. Installation Considerations


Each DPS-100D directional coupler/sensor should be placed in the desired location for measurement. Each supplied directional coupler has a set of measurement ports, one for forward power and the other for reflected power. There is also provision for external temperature and line pressure sensors. Each DPS-100D has an internal temperature sensor for measurement of internal electronics temperature.

1. Install the coupler making sure that the flow of RF follows the arrow direction marked on the coupler. Failure to do this will provide erroneous power indications as they will be reversed.
2. Using standard Ethernet cable attach a cable from the rear panel of the SWP-206 chassis using the supplied DSUB9M to RJ45 adapter. This adapter should be plugged in to the DSUB9F connector marked RS485. Connect the other end of this cable to the first DPS-100D RJ45 receptacle marked RS485. Note that each DPS-100D sensor has two RJ45 receptacles marked RS485. The second connector is used to connect to the next DPS-100D sensor and so on until the last sensor is connected in a "daisy chain" connection method.

IV. Rack Equipment Location and Connection

1. In a suitable EIA 19" rack enclosure mount the SWP-206 chassis. ***It is strongly recommended that the SWP-206 be plugged into a personal computer style UPS system if the system is to be used where interlock control of broadcast transmitters is contemplated.***
2. Attach the supplied DSUB9M to RJ45 adapter to the rear panel DSUB9F connector marked RS-485.
3. Using the supplied Ethernet cables attach one Ethernet cable to the RJ45 receptacle of the adapter installed in step 2 to the first sensor in the system. Using supplied cable daisy chain attach from one sensor to the next until all sensors supplied have been connected. Each DPS-100D sensor has been supplied with its own RS485 address 1 through 8. The data for each sensor will appear on the respective SWP-206 channel. Note that when the DPS-100D sensors are used in conjunction with the SWP-206 chassis they are powered through the RS-485 connection. Make sure all connections are complete and all DPS-100D sensors show an active display. Each DPS-100D sensor has an RS-485 address. This address is programmed at the factory but it is possible to change this address if desired. To perform this change consult the DPS-100D Technical Reference Manual supplied with the DPS-100D sensor. NOTE: No two DPS-100D sensors can have the same RS-485 address or the system will fail to operate properly. See Fig. 1 below

Connect Provided
Category 6 Cable from
SWP-206 Chassis to first
DPS-100D sensor



Connect Provided Category 6
Cable To next DPS-100D
Sensor or for the last DPS-100D
Sensor install provided
RS-485 terminating adapter

Fig. 1 Shows connection from SWP-206 Chassis and to succeeding DPS-100D Sensors

4. Once all DPS-100D sensors have been connected their local displays should be lit and should display the normal operating screen which shows Forward/Reflected Power,

Temperature, Pressure and other data. Note that when properly connected and addressed the SWP-206 channels will show power indication. For channels where no sensor is associated the power indication will be a series of dotted lines indicating no data available. If for some reason a desired channel is not showing data when connected to a DPS-100D sensor, check the cabling to make sure it is seated properly and check the display ICON under COMMS. Review Fig.2 below. Also be sure that the SWP-206 channel has been enabled for the DPS-100D sensor in question. To enable/disable channels see instructions in section VII. Operation for instructions.




Fig. 2

Optional Connections:

When optional BDI temperature and pressure sensors are attached to the DPS-100D RF sensor a complete set of data including forward/reflected power, temperature and pressure can be displayed on the SWP-206 chassis for the respective DPS-100D channel. Normal operation of the SWP-206 chassis displays forward/reflected power. To access the temperature and pressure readings use the left/right arrow keys on the respective channel to access the second screen indicating temperature and pressure.

BDI TMP-100 can be attached to any DPS-100D. The DPS-100D provides power for the sensor. A three position plug is supplied with each TMP-100 for direct plug in to the DPS-100D sensor

BDI PSW-100 Pressure sensors can be connected in a similar fashion to the temperature sensor described above.

V. Transmitter Interlock Connections

Please refer to the diagram below for this discussion. A set of form C relay contacts is available to connect to the respective transmitters connected to the system. A DSUB25F connector on the rear of the SWP-206 chassis is designated as “Interlocks” for this purpose. Connection information is illustrated in the diagram below. Depending on options ordered up to three sets of 8 Interlock relays can be connected. The diagram below is identical for all three Interlock connectors and operation described below is identical for all Interlock relay boards.




Fig. 3 Rear Panel J8 Interlock 1 Connector Diagram

The above connection diagram is the suggested method of wiring interlocks to the respective transmitters connected to the system.

The SWP-206 can be used in four different interlock configurations. Refer to the chart below for configuration information. The four interlock modes are defined as follows:

8 Narrow band channels: Each channel has an independent interlock relay which opens if a reflected power fault occurs on the respective channel or if the external interlock input has

been opened such as on the DPS-100D sensor itself. This jumper is provided to tie into a lock out tag out system or patch panel for safety purposes.

CH 1 Broad band, CH2-8 Narrow Band: If this mode is chosen any fault on channel 1 will cause all 8 interlock relays to open simultaneously. An example of its use is for master antenna applications where only one broad band output such as a single antenna feed is being monitored and the rest of the channels are monitoring station specific transmission lines such as each transmitter feed to a combiner. Relays 2 through 8 will open if a respective channel fault occurs.

CH1-4 Broad Band, CH5-8 Narrow Band: This mode is often used where there is an upper and lower bay of an antenna, a broad band output of a combiner and a system reject load. A reflected power fault or external interlock input fault on any of channels 1 through 4 will cause all of the interlock relays to open. If a fault occurs any of channels 5 through 8 only the respective channel numbered relay will open. These channels are often used to measure up to four narrow band inputs to a combiner system.

8 Broad Band Channels: When this mode is selected any reflected power fault on any channel will cause all 8 relays to open simultaneously.

J3 FLT RST/ I.C. Rear Panel DB-25 INPUT CONFIGURATIONS

DB-25 Pin 8	DB-25 Pin 9	Channel Configuration
OPEN	OPEN	8 NARROWBAND CHANNELS
COM	OPEN	CH1 BROADBAND, CH2-8 NARROWBAND
OPEN	COM	CH1-4 BROADBAND, CH5-8 NARROWBAND
COM	COM	8 BROAD BAND CHANNELS

Fig. 4

DSUBF25 PIN 6 – Remote Fault Reset – for connection to a wired remote control. Momentary closure to pins 19 or 20 which are common pins will cause a fault reset. If the fault condition has cleared the interlock relays will re-energize allowing transmitters connected to restart.

DSUB25F Pin 7 – All channel master interlock input (**MUST be connected to COM for any interlock relay to close**)




Fig. 5 SWP-206 Rear Panel J3 IL/CFG connector

VI. Remote Control/External Interlock Connection

The SWP-206 chassis provides transmitter interlock control based upon information from the DPS-100D sensors connected. In addition there is an external interlock string connection for each SWP-206 channel which is provided on the SWP-206 rear panel DSUB25F connector marked “**J1 Remote Control**”. External interlock inputs can be used to interface to patch panels or lock out tag out devices or any interlock related connection where transmitter operation should be interrupted due to a switch closure. A DSUB25M connector and hood are provided marked JI R/C/S for installation to this connector. Each of the eight external interlock inputs is jumped out on this connector. To interrupt these connections to add external interlock devices pertaining to a particular channel make connections as shown.

There is provision for reflected power fault status for each channel. There is also provision for fault reset. See Fig. 6 for connection information. Note that status is active low. Remote fault reset is accomplished by momentary connection from pin 24 to any CMD/STATUS COM pin.




Fig. 6 SWP-206 Rear Panel J1 R/C/S Connector

Optional RF Status Panel Connection Information

The SWP-206 can be ordered with the RFS-100 RF status LED indicator panel. If this option is ordered make connection between the SWP-206 rear panel connector J2 RF Presence and the DB25 connector marked RF Presence on the RFS-100 RF Status Panel with the provided 6 foot DB25 M/F cable. This panel shows active display of DPS-100D sensors connected as to whether RF is present or not. Note that on unused channels the default is "RF ON"

VII. Operation

Operation of the SWP-206 requires minimal user input. A channel may be manually selected using the up and down arrow keys. Pressing the "X" key momentarily will cause the SWP-206 to enter **AUTO** mode which will continuously cycle between all enabled channels allowing both to be viewed with no user intervention. Auto mode is denoted by an asterisk (*) appearing in the lower left hand corner of the display. Alternate presses of the RED "X" key will cause the SWP-206 to alternately be in Auto or Manual mode. In manual mode using the up/down arrow keys allows the selection of a particular channel for display. To disable unused channels from the scan group follow these instructions:

1. Enter the manual operation mode by pressing the RED "X" key on the front panel of the SWP-206 until the * is extinguished.
2. Select the channel to be disabled by using the up/down arrows to navigate to that channel.
3. Press and hold the GREEN Check mark key for 5 seconds. The unit will enter the programming mode.
4. Using the left/right arrow keys select to enter the channel enable/disable mode.

5. Using the up/down arrow keys select "DISABLE"
6. Press and hold the RED X key for five seconds to store the information.

Enabling channels follows the same procedure except for step 5 select "ENABLE"




Fig. 7 SWP-206 Front Panel Button Cluster

Fault Reset: If the SWP-206 detects a fault condition it will alternate between the normal display and a **"FAULT DETECTED"** warning message. Pressing the RED "X" key momentarily will reset the fault condition and close the interlock relays. If the condition which precipitated the original fault is still present, the SWP-206 will return to the FAULT mode and open the interlocks after a three strike detector timeout. There is provision for remote fault reset on the rear panel of the unit for dry contact closure and through an optional LAN web interface. See section VI. Interlock connections for a pin diagram of the **J3 INTERLOCK/CFG** connector for fault reset and interlock configuration.

SWP-206 LAN Access Configuration

To configure the SWP-206 for LAN operation, open a browser window and enter the default IP address for the SWP-206. **The factory default IP address is: 192.168.1.107**

The Login Screen will look like this:



Select Setup and you will navigate to the setup screen

Default Username: username

Default Password: password

The “Update F/W” button is used for firmware upgrade and if pressed will put the unit in bootloader mode. Unless instructed by the factory avoid pressing this button. If you accidentally press this button simply power cycle the unit. When in bootloader mode SNMP and normal HTML5 browser interface connection is interrupted.

bdi www.broadcast-devices.com

SWP-206 Setup

Firmware Revision: 5.10.7, MAC: 00:00:00:00:00:00

Unit Name	User Name	Password
SWP-206	username	password
SNMP Read Community	SNMP Write Community	SNMP Port
public	private	161
IP Address	IP Mask	Default Gateway
192.168.1.110	255.255.255.0	192.168.1.1
DNS		
192.168.1.1	Save	

Once logged in the IP configuration screen allows the user to change the Unit Name, Username, Password, SNMP Read Community, SNMP Write Community, SNMP Port, IP address, subnet mask and default gateway and DNS if used to match local LAN configuration. Contact your network administrator to obtain the correct settings. Click the [OK] button after changes are made.

NOTE: Be sure to record the new IP address before applying settings (see below). Failure to record the new settings may cause difficulties in locating the SWP-206.

It is a good idea to record your settings here for future reference:

IP Address: _____ SNMP Port: _____

Sub net mask: _____ SNMP Read: _____

Primary DNS Server: _____ SNMP Write: _____

Default Gateway: _____

Serial Data Port: _____

Username: _____


Password: _____

When all data has been entered and recorded here click on the checkmark key to save your settings. YOU MUST POWER CYCLE THE UNIT FOR THESE CHANGES TO TAKE EFFECT OR THE UNIT WILL STILL BE SET TO FACTORY DEFAULTS.

VIII. BDI Stack Graphical User Interface

BDI provides a graphical user interface software package which is designed to operate in a Windows XP/7/8/10 operating system environments and Android devices. The Stack program is contained on the CD supplied with your unit. It can also be downloaded from the support page on our website: www.broadcast-devices.com

Typical GUI Screen shot



The BDI Stack GUI can be used with up to 6 different BDI products simultaneously from collocated or non-collocated equipment.

IX. SNMP v2 Connectivity

The SWP-206 system is an SNMP v2 agent device and can be interfaced by Ethernet connection to SNMP enabled software and hardware. This allows for a simple single CAT5 connection. The CD supplied with the system contains MIB files for all of BDI's SNMP capable products. Use the SWP MIB for this product. To test connectivity, interrogate and make changes to the channels names, etc. we recommend the use of an MIB browser. There are many free MIB browsers available. We recommend the free MIB browser available from www.ireasoning.com. Download and install this or your favorite MIB browser for access to the system by PC.

X. Warranty

Broadcast Devices, Inc. Limited Product Warranty

Broadcast Devices, Inc. ("BDI") products are warranted against failure due to faulty materials or workmanship for a period of one (1) year from the date of shipment to the ultimate user. The warranty covers repair or replacement of defective parts at the factory, provided the unit has been returned prepaid by the user. All shipments to the factory shall have a Returned Material Authorization (RMA) number affixed to the outside of the container, obtained from the factory. The above warranty is void if the unit has been modified by the user outside any factory recommendations or if the unit has been abused or operated outside its electrical or environmental specifications. If customer conducted field tests suggest that the unit may be faulty, whether the unit is in warranty, a full report of the difficulty should be sent to the Broadcast Devices, Inc. factory. The factory may suggest further tests or authorize a return for factory evaluation.

Units sent to the factory should be well-packed and shipped to Broadcast Devices, Inc. The current shipping address can be found by visiting our main web page: www.broadcast-devices.com. Remember to affix the RMA number to the outside of the carton. Any packages received without such an RMA number will be refused. Note: Freight collect shipments will also be refused. When the unit has been received, inspected, and tested, the customer will receive a report of the findings along with a quotation for recommended repairs that fall outside the standard warranty. Units returned for in-warranty repairs that are found not to be defective will be subject to an evaluation and handling charge. In-warranty units will be repaired at no charge and returned via prepaid freight.

Out-of-warranty units needing repair require a purchase order and will be invoiced for parts, labor, and shipping charges.

When ordering a replacement part, contact any authorized reseller of Broadcast Devices, Inc. Always specify A) Part Description, and Quantity; B) Date of Purchase, Where Purchased; C) Any Special Shipping Instructions. Always specify a street address, as shipping companies cannot deliver to a postal box.

BDI. is not responsible for any other manufacturer's warranty on original equipment. Nor are we responsible for any failure, damage, or loss of property resulting from the installation or operation of our equipment outside the recommended specifications.

Broadcast Devices, Inc. reserves the right to change materials, specifications, and features at any time.

BROADCAST DEVICES, INC. MAKES NO WARRANTY, EXPRESS OR IMPLIED, OTHER THAN AS SPECIFICALLY STATED ABOVE. EXPRESSLY EXCLUDED IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR PURPOSE. THE FOREGOING SHALL CONSTITUTE ALL OF BDI'S LIABILITY (EXCEPT AS TO PATENT INFRINGEMENT) WITH RESPECT TO THE BDI PRODUCTS. IN NO EVENT SHALL SELLER BE LIABLE FOR SPECIAL, CONSEQUENTIAL, OR INCIDENTAL DAMAGES, INSTALLATION COSTS, LOST REVENUE OR PROFITS, OR ANY OTHER COSTS OF ANY NATURE AS A RESULT OF THE USE OF BDI PRODUCTS MANUFACTURED BY BDI, WHETHER USED IN ACCORDANCE WITH INSTRUCTIONS OR NOT. UNDER NO CIRCUMSTANCES SHALL BDI'S LIABILITY TO BUYER EXCEED THE ACTUAL SALES PRICE OF THE PRODUCTS PROVIDED HEREUNDER. NO REPRESENTATIVE IS AUTHORIZED TO ASSUME FOR BDI ANY OTHER LIABILITY IN CONNECTION WITH RF PRODUCTS.



Broadcast Devices, Inc.

Westchester Industrial Complex
3199 Albany Post Road, Suite 122
Buchanan, New York 10511 USA

Phone: +1 (914) 737-5032

Email: customer.service@broadcast-devices.com

Web: <https://broadcast-devices.com>

XI. Specifications

Electrical Power Requirements:	100 -240 VAC 50-60 Hertz
Physical Environment:	0 - 55 C non condensing atmosphere
Physical Size:	19"W X 1.75" H X 10" D 1 - EIA Rack Unit
GPIO:	Ground Start/TTL compatible Status
Interlock Relays:	8 – Form C 30 VDC @1 Ampere Contact Rating - Up to 24 with optional additional relay boards
Communications:	Parallel R/C, TCP/IP – SNMP v2
Power Measurement Range:	0 – 1 Mega Watt – configuration dependent
Power Measurement Accuracy:	+/- 5% of reading
Number of channels:	8 forward, 8 reflected